



## City of New London

Department of Finance-Purchasing Agent

13 Masonic Street • New London, CT 06320 • Phone (860) 447-5215 • Fax (860) 447-5297

### Invitation for Bids

#### ADDENDUM

**Bid No.:** 2018-11

**Addendum No.:** 4

**Date Issued:** 8/14/2018

**Green Harbor Beach and Pequot Avenue Storm Drainage**

**Opening Date and Time:** August 16, 2018 @ 2:00 P.M.

**Bidders Notes:** This Addendum is issued to provide all bidders with notice of answers to additional questions submitted by interested parties.

**PLEASE NOTE THAT ONLY CONTRACTORS THAT ATTENDED THE MANDATORY SITE VISIT ON AUGUST 7, 2018 ARE ELIGIBLE TO BID ON THIS PROJECT.**

All other terms and conditions remain the same.

**This Addendum cover page must be signed and returned with your bid.**


\_\_\_\_\_  
Authorized Signature of Bidder

\_\_\_\_\_  
Company Name

#### **Return Bid To:**

Dedra Aker, Purchasing Agent  
City of New London  
13 Masonic Street  
New London, CT 06320

**Bids cannot be accepted after the Bid Opening Date and Time indicated above.**



## **City of New London**

Department of Finance-Purchasing Agent

13 Masonic Street • New London, CT 06320 • Phone (860) 447-5215 • Fax (860) 447-5297

### **ADDENDUM 4**

#### **Additional Questions and Answers for Bid No. 2018-11 Green Harbor Beach and Pequot Avenue Storm Drainage:**

**Question 1:** For the 48" bend, can we use an import bend as an alternate to domestic because of the suppliers are showing a lead time of 8-12 weeks? This timeline does not fit our construction schedule.

**Answer:** Use of an imported 48" DIP bend is permitted provided it meets the material requirements of the specifications.

**Question 2:** Are there are constraints with the permitting (Army Corp of Engineers) of working in the water at the proposed depth?

**Answer:** The Army Corps of Engineers has reviewed the project and has not issued any conditions for construction.

**END OF ADDENDUM 4**